

## EMALAHLENI LOCAL MUNICIPALITY



**ELM 26/2020**

### **Tender Addendum**

**Date: Tuesday, 18 August 2020**

---

**IMPORTANT:** Tenderers are required to attach this tender addendum to the Original Tender Document

---

Further to Request to Tender Number 26/2020 - Panel of service providers for the supply and delivery of electrical components/items for a period of 24 months (on an as and when required basis), tenderers are advised of the following change(s) or clarification(s) to the Tender Document.

#### **Amendments:**

**1. Description of Works (page 65)**

**Tenderers are advised to ignore the item descriptions listed below as they do not form part of the required scope of work:**

<b>Stock Code</b>	<b>Item Description</b>
3008/05/01	Transformer KwaGuqa
3009/02/01	Transformer KwaGuqa
3011/09/01	Transformer KwaGuqa
3012/06/01	Transformer KwaGuqa

**2. The cables should conform to the following specifications:**

The cable should comply with **South African Bureau of Standards (SABS)**

The cable should conform to the compulsory specifications for South African electrical cables as follows:

SANS 1507: Low voltage PVC and XLPE insulated cables ( includes armoured cables)

SANS 1418: LV aerial bundled conductors

SANS 97: Paper-insulated metal sheeted cables up to 33 kV

SANS 1339: XLPE insulated cables up to 33 kV

SANS 182: Overhead line conductors

—  
All other terms and conditions remain unchanged.

**[end of Tender Addendum]**

---

---

We hereby acknowledge receipt of the above referenced Addendum to the Request to Tender and the Tender Addendum shall be incorporated into our Tender submission.

Name of Company: \_\_\_\_\_

Signature of Authorised  
Representative: \_\_\_\_\_

Name/Title [print]: \_\_\_\_\_

Date: \_\_\_\_\_

---

---